

1. AMENDMENT/MODIFICATION NO. 0002		2. EFFECTIVE DATE DEC. 06, 2002	
3. ISSUED BY DEPARTMENT OF THE ARMY, BALTIMORE DISTRICT CORPS OF ENGINEERS P.O. BOX 1715 BALTIMORE, MARYLAND 21203-1715			
4. NAME AND ADDRESS OF CONTRACTOR (Name, street, county, State and ZIP Code)		4A. AMENDMENT OF SOLICITATION NO. DACW31-03-B-0004 <hr/> 4B. DATED (SEE ITEM 5) NOV. 21, 2002	
5. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is not extended. BID OPENING DATE - 11:00 AM, Local Time DEC. 20, 2002 Others must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 4 and 8, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of the amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.			
6. ACCOUNTING AND APPROPRIATION DATA (If required) WEST FILTER INSTRUMENTATION WASHINGTON AQUEDUCT DIVISION, WASHINGTON, DC			
7. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) SEE THE FOLLOWING PAGES			
8. NAME AND TITLE OF SIGNER (Type or print)		9. CONTRACTOR/OFFEROR <hr/> (Signature of person authorized to sign)	10. DATE SIGNED

SPECIFICATIONS

1) Page 01005-3, Paragraph 1.3.7.3.c.3): Delete "between September 15, 2002 and" and replace with "prior to".

2) Page 13621-1, Paragraph 1.1.2.4: Delete "Sec. 1.2.1.2.1" and replace with "paragraph 1.2".

3) Page 13631-7, Paragraph 2.4.7: ADD the following to the end of the paragraph:

"These items are not included in Bid Item 0001. The Contracting Officer shall determine which recommended items shall be provided. Provision of these items shall be in accordance with the "CHANGES" clause of the Contract clauses."

4) Section 13801 - Rehabilitation of Venturi Meters:

a) Paragraph 3.2.2: Add the following paragraph:

"3.2.2.4 Inspection report shall be submitted for each venturi to the Contracting Officer within 2 weeks of the shutdown for its removal."

b) Paragraph 3.6.2

Starting with "Once the meter...": change the paragraph number to read 3.6.3.

c) Paragraph 3.6.3

Starting with "Once the calibration...": change the paragraph number to read 3.6.4.

d) Paragraph 3.6.4: Immediately following this paragraph, insert the new paragraph as shown below:

"3.6.5 Venturi shall be re-installed and calibrated within 3 weeks of the shutdown for its removal, unless notified otherwise by the Contracting Officer."

CONTRACT DRAWINGS

5) Plate 2, Building Plans and General Notes:

a) Note #5: Delete "10 TONS GVW" and replace with "5 TONS GVW".

b) Add General Note 17 as follows:

"17. The overhead monorail and hoist is manually operated and has a capacity of 3 tons. The Government shall not be responsible for delays resulting from any operational problems that may arise with the overhead monorail and hoist."

6) Plate 6: Delete this plate as originally issued and substitute therefore the attached revised same like-numbered plate dated December 5, 2002.

7) Plate 12, P&ID Symbols and Legend, Indicating Light Unit:

a) Delete "G - Green (Off, Stop, Open)" and replace with "G - Green (Run, Start, Close)".

b) Delete "R - Red (Run, Start, Close)" and replace with "R - Red (Off, Stop, Open)".

8) Plate 18, Filter Building North - Pipe Gallery Electrical Plan, Notes: Add Note 3 as follows:

"3. New Lighting Panels (LP) shall be installed in the same location as the existing panels. Location of these panels on the Drawings shown only for clarity."

9) Plate 20: Delete this plate as originally issued and substitute therefore the attached revised same like-numbered plate dated December 5, 2002.

ATTACHMENTS

Plate 6, revised December 5, 2002.
Plate 20, revised December 5, 2002.